

**STATE OF INDIANA
DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

PUBLIC NOTICE NO. 99-12-F-RD-P

DATE OF NOTICE: December 18, 1999

DATE RESPONSE DUE: February 21, 2000

The Office of Water Management proposes the following permit actions listed below:

NPDES PERMIT-PROPOSED/MAJOR-RENEWAL

INDIANAPOLIS BELMONT ADVANCED WASTEWATER TREATMENT PLANT,
2700 South Belmont Avenue, Indianapolis, Indiana, NPDES Permit No. IN0023183. IDEM is processing the renewal of the NPDES permit to discharge 120 million gallons per day of treated sanitary wastewater into the West Fork of the White River located in MARION COUNTY. The City of Indianapolis owns the municipal wastewater treatment plant and White River Environmental Partnership operates it. Proposed effluent parameters to be limited and/or monitored at Outfall No. 006: flow, CBOD₅, TBOD₅, total suspended solids, ammonia-N, fecal coliform, E.coli, pH, total residual chlorine, dissolved oxygen, cyanide, mercury, chlorides, fluorides, sulfates, and total dissolved solids. There are 133 combined sewer overflows in the collection system listed in Attachment A. These overflows discharge into the White River, Big Eagle Creek, Bean Creek, Pleasant Run, Little Eagle Creek, Pogues Run, Fall Creek, State Ditch and Lick Creek. There are 2 sanitary sewer overflows in the collection system which are identified in Attachment B. These overflows discharge into Meadow Brook and Blue Creek. Permit Writer: Roger Rylatt at 317/232-8619. Published in the **Indianapolis Star**.

INDIANAPOLIS SOUTHPORT ADVANCED WASTEWATER TREATMENT PLANT,
3800 West Southport Road, Indianapolis, Indiana, NPDES Permit No. IN0031950. IDEM is processing the renewal of the NPDES permit to discharge 125 million gallons per day of treated sanitary wastewater into the West Fork of the White River located in MARION COUNTY. The City of Indianapolis owns the municipal wastewater treatment plant and White River Environmental Partnership operates it. Proposed effluent parameters to be limited and/or monitored at Outfall No. 001: flow, CBOD₅, total suspended solids, ammonia-N, fecal coliform, E.coli, pH, total residual chlorine, dissolved oxygen, cadmium, cyanide, mercury, chlorides, fluorides, sulfates, and total dissolved solids. Permit Writer: Roger Rylatt at 317/232-8619. Published in the **Indianapolis Star**.

PUBLIC NOTICE

GENERAL INFORMATION

Procedures for the Formulation of Final Determination

A. Comment Period

The proposed determination to issue these permits is tentative. Interested persons are invited to submit written comments on the proposed permits. Deliver or mail all requests or comments to:

Indiana Department of Environmental Management
Municipal Permits Section
Office of Water Management
100 North Senate Avenue
P.O. Box 6015
Indianapolis, Indiana 46206-6015

All comments must be postmarked no later than the above date to be considered in the formulation of the final determination.

B. Public Hearing

IDEM plans to schedule a public hearing concerning the proposed permits. Notice of the public hearing will be made at a later date.

Availability of Additional Information

The application, proposed permits, and related documents, comments received, and other pertinent information are on file and may be inspected in Room 1203, Indiana Department of Environmental Management, 100 North Senate Avenue, Indianapolis, Indiana, at any time between 9:00 a.m. and 4:00 p.m., Monday through Friday. All of these documents may be copied at a cost of 10 cents per page. Copies of the draft permits are also on file with the local health department and should be available for review. The draft permits and the fact sheets will also be available on the Internet at www.state.in.us/idem/owm. Please bring the foregoing to the attention of persons whom you know would be interested in this matter.